

ADDENDUM NO. 2
FOR
CITY OF JACINTO CITY
TO
LJA Project No. 086-040A & D
GENERATORS

December 5, 2011

CONTRACT DOCUMENTS

WORKING DAYS:

Change Working Days from 80 Working Days to 120 Working Days.

SPECIFICATIONS:

Item 16040 – Electrical Emergency Generators

Generator units manufactured by Waukesha – Pearce (Generac) are not an approved equal.

CLARIFICATIONS:

1. Whether Diesel or Natural Gas Fuel Generators, it will be the responsibility of the Contractor to confirm the generators, to be provided by Contractor, can be installed within the perimeters shown in the Contract Documents.
2. Projects with Natural Gas Fueled Generators – It will be the Contractor’s responsibility to provide the following:
 - a. Gas service connection from meter to generator, both labor and materials
 - b. Gas meter will be responsibility of the Contractor.

END OF ADDENDUM NO. 2