

**ADDENDUM NO. 3**  
**FOR**  
**CITY OF JACINTO CITY**  
**TO**  
**LJA Project No. 086-040A & D**  
**GENERATORS**  
**December 7, 2011**

**SPECIFICATIONS:**

**ITEM 16040 – Electrical - Emergency Generators**

**Section II – MATERIALS**, Paragraph C Unit Requirements, Number 5, **DELETE** UL 1085 – Fuel Tank Storage and **REPLACE** with UL 2085 Fuel Tank Storage.

**Section IV – QUALITY ASSURANCE**, Paragraph E Warranties **ADD** the following paragraphs.

**ENGINE - GENERATOR:** Standard one year from date of Owner's acceptance of the project and signature.

**GENERATOR ENCLOSURE:** Three years from date of Owner's acceptance of the project and signature.

**CLARIFICATIONS:**

1. Enclosure – Sound attenuated (75 dba @ 7 Meters)
2. 60 kW Diesel Generators (Lift Stations #1 and #2)
  - a. A permanent mounted load bank outside of enclosure next to generator in NEMA 3R cabinet is acceptable.
  - b. Load bank for 2 Each 60 kW Diesel Generators will be 100% rated.

**END OF ADDENDUM NO. 3**